

IMSA 20-4 19AWG



Product Description: Paired bare copper conductors conforming to ASTM B-3 before insulating. Insulated with Polyethylene (per UL 62, ASNI C33.1 except for cold bend test shall be minus 55°C). Twisted with overall copper tape applied with an over lap of at least 15% of its width. Jacketed with a high quality Class 2 Polyethylene (per UL 62 ANSI C33.1). Sunlight resistant (per UL 854 ANSI C33.51)

Rated at 600V. Indent printed

Non-wicking, non-metallic moisture resistant fillers are used when needed to make round

USE: For use in aerial installation for Fire Protective signaling or as traffic signal cable.

Suitable for use in wet or dry locations at 75°C

P/N	AWG	# PAIRS	STRAND	INS THICKNESS	JACKET THICKNESS	Web Thick	High
982P1920-4	19	2	SOLID	.025	.045 X .050	.075	.100
982P19X20-4	19	2	STRANDED	.025	.045 X .050	.075	.100
984P1920-4	19	4	SOLID	.025	.045 X .050	.075	.100
984P19X20-4	19	4	STRANDED	.025	.045 X .050	.075	.100
985P1920-4	19	5	SOLID	.025	.045 X .050	.075	.100
985P19X20-4	19	5	STRANDED	.025	.045 X .050	.075	.100
986P1920-4	19	6	SOLID	.025	.060 X .050	.075	.100
986P19X20-4	19	6	STRANDED	.025	.060 X .050	.075	.100
988P1920-4	19	8	SOLID	.025	.060 X .050	.075	.100
988P19X20-4	19	8	STRANDED	.025	.060 X .050	.075	.100
9810P1920-4	19	10	SOLID	.025	.060 X .050	.075	.100
9810P19X20-4	19	10	STRANDED	.025	.060 X .050	.075	.100
9812P1920-4	19	12	SOLID	.025	.060 X .050	.075	.100
9812P19X20-4	19	12	STRANDED	.025	.060 X .050	.075	.100
9815P1920-4	19	15	SOLID	.025	.060 X .050	.075	.100
9815P19X20-4	19	15	STRANDED	.025	.060 X .050	.075	.100

These values are nominal in accordance with industry standards.

Additional gauges and conductor count available.

Additional colors and State specific specs available upon request.

Color Code Chart: 8

Voltage: 600V

Temperature: 75°C



FALCON FINE WIRE AND WIRE PRODUCTS, INC.
 2401 DISCOVERY BLVD • ROCKWALL, TEXAS 75032
 214-771-3441 • 972-722-9168 • falconwire@aol.com